


05.9089.B

20 July 2006



**EUROBODALLA SHIRE COUNCIL**

*Good Government, better living*

ONE TREE CONSTRUCTIONS  
PO BOX 3056  
TUROSS HEAD 2537

PO Box 99 Moruya NSW 2537  
email: council@eurocoast.nsw.gov.au  
website: www.esc.nsw.gov.au  
DX 4873

Dear Sir/Madam,

**Notice of Compliance Inspection:-**

Property Description	<b>86 TRAFALGAR ROAD, TUROSS HEAD - DP 519374, Lot 2</b>
Application Number	<b>712/05</b>
Inspection Type	<b>Final Plumbing &amp; Drainage</b>
Inspection Date	<b>19/07/2006</b>

Please be advised that the above inspection undertaken by Council was defective for the following reason/s:-

- 1. Gutter guard to be installed as per Council's Policy & Code of Practice for rainwater tanks.**
- 2. Outside shower is not allowed to connect to stormwater overflow which terminates to the street.**
- 3. Outlet from rainwater tank to be protected from mosquitoes & insects entering.**
- 4. Works as executed plan to be submitted showing the tank location, stormwater drainage & non-potable cold water reticulation to the building.**
- 5. A completed works as executed standard tank detail as shown in figures 9 & 10 of Council's Code of Practice for rainwater tanks. (Enclosed)**

Please contact me on telephone number (02) 44741277 if you have any queries regarding this matter.

Yours faithfully

Paul Scholze  
Drainage Inspector